


STANDARD DRAWING NO. 131
LARGE DIAMETER (5' OR LARGER) MANHOLE
 N.T.S.

- NOTES:**
1. THE PRECAST BASE SHALL HAVE THE FLOOR AND SIDE WALL CAST AS ONE UNIT. THE FLOW LINE (CHANNEL) AND BENCHES SHALL BE CAST SEPARATELY FROM THE FLOOR AND SIDE WALL AT THE PLACE OF MANUFACTURE.
 2. WAIT A MINIMUM 24 HOURS AFTER POUR BEFORE BACKFILL PLACEMENT AROUND POURED BASES.
 3. WHERE CALLED FOR ON PROFILES, LINING SHALL BE PER SPEC. SECTION 02806.
 4. SEE SPEC. SECTION 02806 FOR EPOXY RESIN MANHOLES.

REVISION	BY	DATE



SANITATION DISTRICT NO. 1
 1045 Eaton Drive
 FT. Wright, Kentucky 41017
 Ph: (859) 578-7460
 Fax: (859) 331-2436

DATE:
AUGUST 2018

STANDARD
DRAWING NO:

132