


NOTE: WHERE FORCE MAINS PARALLEL GRAVITY SEWERS, FITTINGS SHALL BE PROVIDED TO MAINTAIN 12" OF SEPARATION BETWEEN ALL PIPES AND MANHOLES

### COMBINED TRENCH DETAIL

N.T.S.

REVISION	BY	DATE



**SANITATION DISTRICT NO. 1**  
 1045 Eaton Drive  
 FT. Wright, Kentucky 41017  
 Ph: (859) 578-7460  
 Fax: (859) 331-2436

DATE:  
**MARCH 2010**

---

STANDARD  
 DRAWING NO:  
**109**